

Rekenwaarde maximum draagkracht in kN per sondering
Berekening volgens Eurocode 7-1 (NEN1997-1:2025)

Sonderingen voor opdracht: 25SP1917															
Prefab betonpaal 0,220 x 0,220 m															
	DKM001	DKM002	DKM003	DKM004	DKM005	DKM006	DKM007	DKM008	DKM009	DKM010	DKM011	DKM012	DKM013	DKM014	DKM015
-8,50						206	241	215	183	186				239	
-9,00						232	280	250	215	207		323		309	
-9,50			201	205		251	284	288	302	238		453		494	
-10,00		412	243	273		526	308	479	384	266	380	520		471	
-10,50	112	451	290	291	193	493	338	601	418	284	470	559	365	448	
-11,00	292	491	425	369	226	484	395	629	543	302	561	599	485	458	
-11,50	360	530	567	509	383	500	419	648	599	319	616	638	529	533	104
-12,00														624	110
-12,50															
-13,00															
-13,50															
-14,00														627	411
-14,50														622	481
-15,00														631	459
-15,50														656	477
-16,00														723	500

diepte tov NAP

Rekenwaarde maximum draagkracht in kN per sondering
Berekening volgens Eurocode 7-1 (NEN1997-1:2025)

diepte tov NAP

Sonderingen voor opdracht: 25SP1917										Prefab betonpaal 0,220 x 0,220 m			
	DKM016	DKM017	DKM018	DKM019	DKM020	DKM021	DKM022	DKM023	DKM024				
-8,50													
-9,00													
-9,50	252												
-10,00	415												
-10,50	428												
-11,00	296		114										
-11,50	254		192										
-12,00	244		290										
-12,50			330										
-13,00			306			107		134	165				
-13,50		140	294			271	230	253	257				
-14,00	475	119	313	193	105	351	254	296	340				
-14,50	511	122	304	199	117	363	268	344	342				
-15,00	487		314		219	320	298	413	352				
-15,50	481	182	326	231	237	326	303	418	377				
-16,00	492	207	409	244	258	347	328	424	432				

diepte tov NAP

Rekenwaarde maximum draagkracht in kN per sondering
Berekening volgens Eurocode 7-1 (NEN1997-1:2025)

Sonderingen voor opdracht: 25SP1917		Prefab betonpaal 0,250 x 0,250 m														DKM015
		DKM001	DKM002	DKM003	DKM004	DKM005	DKM006	DKM007	DKM008	DKM009	DKM010	DKM011	DKM012	DKM013	DKM014	
-8,50							247	292	259	222	227				291	
-9,00							287	336	306	263	256		407		383	
-9,50				247	254		306	349	357	378	294		561		614	
-10,00			535	298	338		628	376	597	475	323	474	658		556	
-10,50	144	580	580	352	354	232	582	411	719	511	345	582	703	458	546	
-11,00	367	595	595	525	451	275	580	474	754	663	364	686	748	593	553	
-11,50	444	670	687	620	468	596	505	765	727	384	745		793	632	649	130
-12,00															756	138
-12,50																
-13,00																
-13,50																
-14,00															727	504
-14,50															725	572
-15,00															733	540
-15,50															761	576
-16,00															845	604

diepte tov NAP

Rekenwaarde maximum draagkracht in kN per sondering
Berekening volgens Eurocode 7-1 (NEN1997-1:2025)

Sonderingen voor opdracht: 25SP1917											Prefab betonpaal 0,250 x 0,250 m			
	DKM016	DKM017	DKM018	DKM019	DKM020	DKM021	DKM022	DKM023	DKM024					
-8,50														
-9,00														
-9,50	325													
-10,00	518													
-10,50	512													
-11,00	351		149											
-11,50	303		240											
-12,00	286		358											
-12,50			392											
-13,00			363			145		183		215				
-13,50		172	356			349	293	309		325				
-14,00	569	144	377	230	133	422	307	368		420				
-14,50	607	148	354	239	146	433	330	428		405				
-15,00	567		372		269	381	363	508		434				
-15,50	560	219	386	274	290	398	372	521		462				
-16,00	572	249	487	288	314	420	400	500		510				

Rekenwaarde maximum draagkracht in kN per sondering
Berekening volgens Eurocode 7-1 (NEN1997-1:2025)

Sonderingen voor opdracht: 25SP1917																Prefab betonpaal 0,290 x 0,290 m															
	DKM001	DKM002	DKM003	DKM004	DKM005	DKM006	DKM007	DKM008	DKM009	DKM010	DKM011	DKM012	DKM013	DKM014	DKM015																
-8,50						308	365	324	279	282				368																	
-9,00						361	410	381	328	326		534		489																	
-9,50			313	329		389	444	459	491	377		721		787																	
-10,00		677	380	434		759	477	772	610	409	614	867		672																	
-10,50	194	714	446	448	291	699	520	887	647	434	741	920	600	691																	
-11,00	481	746	675	575	343	705	591	935	838	456	842	972	744	693																	
-11,50	568	820	867	788	594	727	618	918	889	478	933	1024	789	816	164																
-12,00														948	171																
-12,50																															
-13,00																															
-13,50																															
-14,00														859	641																
-14,50														868	720																
-15,00														874	650																
-15,50														909	710																
-16,00														1016	755																

diepte tov NAP

Rekenwaarde maximum draagkracht in kN per sondering
Berekening volgens Eurocode 7-1 (NEN1997-1:2025)

Sonderingen voor opdracht: 25SP1917										Prefab betonpaal 0,290 x 0,290 m			
	DKM016	DKM017	DKM018	DKM019	DKM020	DKM021	DKM022	DKM023	DKM024				
-8,50													
-9,00													
-9,50	437												
-10,00	674												
-10,50	625												
-11,00	425		203										
-11,50	381		313										
-12,00	342		459										
-12,50			478										
-13,00			440			204		264	290				
-13,50		216	443			468	390	383	431				
-14,00	706	180	468	280	175	516	376	474	513				
-14,50	746	185	434	297	186	527	421	550	502				
-15,00	673		454		345	461	440	627	548				
-15,50	675	276	467	335	366	502	474	674	588				
-16,00	684	309	600	351	396	526	506	605	613				

diepte tov NAP